

TIFFIN FIRE/RESCUE DIVISION

53 S. MONROE ST.
TIFFIN, OHIO 44883-2836
OFFICE: 419-448-5444 FAX: 419-448-5421

FIRE CHIEF ROBERT CHAPPELL
E-MAIL: FIRECHIEF@TIFFINOHIO.GOV

DEPUTY CHIEF MIKE HOMAN
E-MAIL: FIREDEPUTYCHIEF@TIFFINOHIO.GOV



Mobile Food Vendor Unit Inspection Safety Requirements

Tiffin Fire Rescue Division will not do a safety inspection for licensure on any mobile food unit not meeting the following minimum criteria listed below. The full inspection form with additional requirements is included in this packet.

1. All mobile food vending units must arrive ready for operation.
2. All systems must be prepared to demonstrate: cooking, electrical, and ventilation.
3. Propane pressure leak test completed within one year of the date of license issue or renewal.
4. Carbon Monoxide Detector- Battery Backup preferable (only if unit contains gas appliances)
5. 5 LB 3A 40BC Dry Chemical Portable Fire Extinguisher
6. 6 L Class K extinguisher is required for units cooking with solid fuels, vegetable oils and fats, and animal oils and fats. This is in addition to the Dry Chemical Extinguisher.

All extinguishers must have a current (within 12 months) inspection tag or a receipt of purchase within the last 12 months

MISSION STATEMENT

“The Mission of the Tiffin Fire and Rescue Division is to protect life and property through dedicated and professional fire and EMS services.”